



**TEST REPORT**

**IQS - 6276**

**Air Leakage Testing**

**GT065 AB**

**Report reference No.** 6276

**Tested by (name and signature):** Jason Leboeuf

A handwritten signature in blue ink, appearing to read 'Jason Leboeuf'.

**Approved by (name and signature):** Michael Morrow

A handwritten signature in blue ink, appearing to read 'Michael Morrow'.

**Date of issue:** 8-Aug-12

**Testing Laboratory Name:** The Compliance Management Group

**Address:** 257 Simarano Drive

**Testing location:** Marlboro, MA 01752 USA

**Applicant's Name:** Custom Plastic Distributors

**Address:** PO Box 672

Putnam, CT 06260

**Test specification** N.A.

**Standard:** N.A.

**Test procedure:** Airflow Test Chamber Testing - Volumetric Flow Measurement

**Procedure deviation:** N.A.

**Non-standard test method:** N.A.

**Test item description:** GT065 AB Floor Grommet

**Trademark:** GT065 AB Floor Grommet

**Model and/or type reference:** GT065 AB Floor Grommet



**GT065AB Air Leakage Testing**  
8-Aug-12

|                    | No Grommet (Open Hole) | Grommet Only (No cables) | 1 x 3/8" Power Cable | 1 x 3/4" Electrical Conduit |
|--------------------|------------------------|--------------------------|----------------------|-----------------------------|
| Static P (in. H2O) | GT065 AB               | GT065 AB                 | GT065 AB             | GT065 AB                    |
| 0.05               | 166.4                  | 1.6                      | 1.9                  | 1.9                         |
| 0.1                | 251.0                  | 1.9                      | 2.2                  | 3.0                         |
| 0.15               | 317.0                  | 2.2                      | 2.7                  | 3.7                         |
| 0.2                | 370.4                  | 3.0                      | 3.2                  | 4.2                         |
| 0.25               | 380.6                  | 3.2                      | 3.5                  | 4.6                         |
|                    | <b>SCFM</b>            |                          |                      |                             |

|                   |                               |
|-------------------|-------------------------------|
| 23                | °C                            |
| 44                | %RH                           |
| 998               | kPa                           |
| 0.06              | Offset                        |
| 0.7"              | Nozzle (DUT)                  |
| 2 x 2"            | Nozzle (Open Hole)            |
| 2 x 2" + 1 x 1.6" | Nozzle (Open Hole, 0.25" H2O) |

Cubic Feet per Minute at Standard Air Conditions  
20°C/68°F, 50% RH, 101.325 kPa/14.696psi

